



Zugbrige Zeichnung / Raised Drawing		Bemerkung / Remark	
No.	Zeichnung Nummer / Drawing No.	Bemerkung / Remark	Änderung / Change
11	148315/00 311 - 0011	Fluence Reaction Duct Arrangement Section A-A, support	
12	148315/00 311 - 0012	Fluence Reaction Duct Arrangement Section B-B, C-C, D-D, rectangles	
11	148315/00 311 - 0013	Fluence Reaction Duct Arrangement Section E-E, F-F, G-G, measurement points	
12	148315/00 311 - 0020	FGRD Head Corner 2,4,6,8, Assembly	
11	148315/00 311 - 0070	FGRD Assembly 141-148 with 150,160	
11	148315/00 311 - 0072	Connecting pieces Mill Ducts, Part 150	
11	148315/00 311 - 0073	FGRD Flange 10 to 80	
11	148315/00 311 - 0095	FGRD Seal to Boiler	
11	148315/00 311 - 0020	Coil Wlecthute HFB,	



SOŠTANJ Unit 6
1 x 600 MW - Power Island
Slovenia

Revision History					
No.	Reason	Created	Checked	Approved	ESD Date
1	148315/00				

Notes:

- All duct work components are to be welded girth.
- Site welds are marked with \blacktriangleright . All welds not marked are shop welds.
- All fillet welds: $a = 5$ mm unless otherwise specified.
- Welds of the metal wall stiffeners have to be carried out as follows unless otherwise specified.
- For welded joints use EN ISO 5817 in applicable quality level C, unless otherwise specified.

Part of the drawing		Drawing list		Revision	
Part List	Inspection and test programme: 148315 / 00 198 - 7071	148315 / 00 198 - 7071	Part List	148315 / 00 198 - 7071	Part List

The parts to be shipped shall be clearly and non-ambiguously marked with:
 Parts to be shipped with a part No. and weight of the part to be shipped.
 Parts to be shipped are indicated with a ∇ in the parts list in column DK or Digi.